



Fire Prevention Bureau, Woodbridge Fire Department

418 School Street • Woodbridge, New Jersey 07095
Business: (732) 602-6050 • Fax: (732) 602-6043
www.woodbridgefireprevention.org

FIRE • POLICE • MEDICAL
EMERGENCIES
DIAL 9-1-1

EXIT SIGN AND EMERGENCY LIGHT MONTHLY TEST LOG

Business name: _____

Person Inspecting Units	Month / Year	Are all exit signs illuminated?	Are the battery back-ups for the exit signs operating properly?	Do all emergency lights illuminate?	Do any units need to be repaired?

MONTH THAT ONE HOUR TEST WAS PERFORMED: _____

Testing for emergency lighting systems, including exit signs, shall be tested for proper operation for a minimum of 30 seconds every month. An annual test shall be conducted for one hour. Equipment shall function properly for the duration of the test.

